

Recommendation to ASHRAE TC 9.9

Liquid Cooling Guidelines HPC Compressorless Liquid Cooling Building Supplied Cooling Water Guideline

HPC User Group
Liquid Cooling subcommittee
June 27, 2011

HPC User Group

- Initiated by LBNL, supported by the DOE-Federal Energy Management Program and now DOE – Sustainability Projects Office
- National laboratories, other Federal Agencies, Universities, Industry HPC operators, HPC manufacturers
- Over 160 members
- Large market presence



Motivation/Goals

- Compressorless cooling can provide significant CAPX and OPEX (energy) savings for HPC facilities.
- Liquid cooling facilitates compressorless cooling.
- Minimize water use - Investigate the feasibility of dry cooling or cooling tower only infrastructure for HPC.
- Develop liquid cooling temperature guidelines to standardize HPC mfg designs and facility requirements. Temperatures should be high enough to eliminate compressor cooling in at least 90% of the National Laboratory HPC locations.
- Liquid cooling guidelines could standardize broader data center cooling applications



Methods

- building water supply guidelines: e.g. supply and return temperature, delta pressure, quality -
- for ~90% of National Labs. (15 sites), design point = 99.6% of hours per ASHRAE
- investigate dry cooler (dry bulb) and cooling tower (wet bulb) infrastructure types
- assume infrastructure design for feasibility study; assume plate frame and CDU components
- document component approach temperatures
- forecast processor case temperature compared to case temperature maximum for continuous operation (Intel Xeon 5500: $T_{case} \sim 76^{\circ}\text{C}$)
- construct supply water temperature guideline table

Liquid Direct Cooling Architectures using Cooling Towers or Dry Coolers



Air Cooled Solution Architectures using Cooling Towers or Dry Coolers



Sort by 0.4% dry bulb (exceeded on average of 3 hours/month)

HPC Data Center Owner	U.S. State	City Name	Lat	Long	Elevation (ft)	Closest ASHRAE Location	Lat	Long	Elevation (ft)	Dry Cooling 0.4% DB (F)	Evap. Cooling 0.4% WB (F)
Pacific Northwest National Laboratory	Washington	Richland	46.285	-119.283	384	Pasco	46.27	-119.12	404	99.5	72.1
Lawrence Livermore National Laboratory	California	Livermore	37.682	-121.767	480	Livermore Municipal Apt	37.69	-121.82	397	98.8	70.8
Houston Texas - Owner TBD	Texas	Houston				Bush Intl. Apt.	29.99	-95.36	105	96.8	80.1
Los Alamos National Laboratory	New Mexico	Los Alamos	35.888	-106.306	7320	Albuquerque Intl Apt	35.04	-106.62	5315	95.2	65.3
Sandia National Laboratory	New Mexico	Albuquerque	35.050	-106.540	5436	Albuquerque Intl Apt	35.04	-106.62	5315	95.2	65.3
Jefferson Laboratory	Virginia	Newport News	37.130	-76.490		New Port News	37.13	-76.49	52	94.5	79.7
Oak Ridge National Laboratory	Tennessee	Oak Ridge	36.010	-84.270	875	Nashville Intl Apt	36.12	-86.69	604	94.4	78.2
National Renewable Energy Laboratory	Colorado	Golden	39.755	-105.220	5675	Denver Stapleton Intl Apt	39.77	-104.87	5285	93.5	64.4
Princeton Plasma Physics Laboratory	Princeton	New Jersey	40.348	-74.659		Mcguire AFB	40.02	-74.6	148	92.9	78.8
SLAC	California	Palo Alto	37.416	-122.202	262	San Jose Intl Apt	37.36	-121.93	49	92.3	69.5
Argonne National Laboratory	Illinois	Argonne	41.711	-87.983	685	Chicago Midway Apt	41.79	-87.75	617	92.1	78.0
Idaho National Laboratory	Idaho Falls	Idaho	43.466	-112.030		Fanning Field Apt	43.52	-112.07	4744	91.7	64.9
Fermilab	Illinois	Batavia	41.850	-88.313	771	Aurora Municipal Apt	41.77	-88.47	705	90.8	77.7
Ames National Laboratory	Iowa	Ames	42.020	-93.640		Ames Muni Apt	42	-93.62	955	90.5	79.2
Brookhaven National Laboratory	New York	Upton	40.883	-72.870	81	Long Island Macarthur Apt	40.79	-73.1	108	88.4	76.7
Lawrence Berkeley National Laboratory	California	Berkeley	37.870	-122.250	1000	Oakland	37.76	-122.22	89	81.8	67.6



Natural Break Points

Sort by 0.4% wet bulb (exceeded on average of 3 hours/month)

HPC Data Center Owner	U.S. State	City Name	Lat	Long	Elevation (ft)	Closest ASHRAE Location	Lat	Long	Elevation (ft)	Dry Cooling 0.4% DB (F)	Evap. Cooling 0.4% WB (F)
Houston Texas - Owner TBD	Texas	Houston				Bush Intl. Apt.	29.99	-95.36	105	96.8	80.1
Jefferson Laboratory	Virginia	Newport News	37.130	-76.490		New Port News	37.13	-76.49	52	94.5	79.7
Ames National Laboratory	Iowa	Ames	42.020	-93.640		Ames Muni Apt	42	-93.62	955	90.5	79.2
Princeton Plasma Physics Laboratory	Princeton	New Jersey	40.348	-74.659		Mcguire AFB	40.02	-74.6	148	92.9	78.8
Oak Ridge National Laboratory	Tennessee	Oak Ridge	36.010	-84.270	875	Nashville Intl Apt	36.12	-86.69	604	94.4	78.2
Argonne National Laboratory	Illinois	Argonne	41.711	-87.983	685	Chicago Midway Apt	41.79	-87.75	617	92.1	78.0
Fermilab	Illinois	Batavia	41.850	-88.313	771	Aurora Municipal Apt	41.77	-88.47	705	90.8	77.7
Brookhaven National Laboratory	New York	Upton	40.883	-72.870	81	Long Island Macarthur Apt	40.79	-73.1	108	88.4	76.7
Pacific Northwest National Laboratory	Washington	Richland	46.285	-119.283	384	Pasco	46.27	-119.12	404	99.5	72.1
Lawrence Livermore National Laboratory	California	Livermore	37.682	-121.767	480	Livermore Municipal Apt	37.69	-121.82	397	98.8	70.8
SLAC	California	Palo Alto	37.416	-122.202	262	San Jose Intl Apt	37.36	-121.93	49	92.3	69.5
Lawrence Berkeley National Laboratory	California	Berkeley	37.870	-122.250	1000	Oakland	37.76	-122.22	89	81.8	67.6
Los Alamos National Laboratory	New Mexico	Los Alamos	35.888	-106.306	7320	Albuquerque Intl Apt	35.04	-106.62	5315	95.2	65.3
Sandia National Laboratory	New Mexico	Albuquerque	35.050	-106.540	5436	Albuquerque Intl Apt	35.04	-106.62	5315	95.2	65.3
Idaho National Laboratory	Idaho Falls	Idaho	43.466	-112.030		Fanning Field Apt	43.52	-112.07	4744	91.7	64.9
National Renewable Energy Laboratory	Colorado	Golden	39.755	-105.220	5675	Denver Stapleton Intl Apt	39.77	-104.87	5285	93.5	64.4

Wet and Dry Bulb Temperatures

ASHRAE CD, 99.6% of yearly hours, National Laboratory HPC Locations.



Thermal Assumptions

Heat Transfer Component	Delta Description	Approach/Delta	
		°F	°C
Open Cooling Tower	WB Ambient to Water Leaving	<u>7</u> ¹	<u>3.8</u>
Dry Fin Cooler	DB Ambient to Water Leaving	<u>10</u> ⁷	<u>5.5</u>
Plate and Frame Heat Exchanger	Cooling Water Entering To Cooled Water Leaving	<u>3</u> ⁵	<u>1.67</u>
Cooling Distribution Unit (CDU) e.g. Water to Water or Refrigerant to Water	Cooling Water Entering To Cooled Water Leaving	<u>5</u> ⁹	<u>2.77</u>
Air to Water Heat Exchanger	Cooling Water Entering To Cooled Air Leaving (server entering)	<u>16.2</u>	<u>9</u> ³
Server Bezel Pre-Heating	Server Air Entering To Chip Air Cooler Entering	<u>5.4</u>	<u>3</u> ⁴
Water Rack Pre-Heating	Rack Water Increase Due to Serial Circuits	<u>9</u>	<u>5</u> ⁸
Chip Air Cooler (heat sink)	Cooling Air Entering To Chip Tcase Max.	<u>0.405</u> °F/watt	<u>0.225</u> ² °C/watt
Chip Liquid Cooler (plate?)	Cooling Liquid Entering To Chip Tcase Max.	<u>0.315</u> °F/watt	<u>0.175</u> ⁶ °C/watt

Thermal Architecture Approach References

- (1) Open Cooling Tower water cooled from 95°F to 85°F using a WB temperature of 78°F – 1996 ASHRAE Systems and Equipment Handbook – page 36.2 – reference to description of nominal cooling tower tons. Approach in this case is 7°F. Colorado Springs Utilities – White Paper #14 3/11/2005 – Smart Use of Your HVAC Cooling Towers – “Approach temperatures lower than 7 degrees encounter diminishing returns and require larger investment in fan horsepower for each additional degree.”
- (2) Air Cooling Heat Sink Performance SGI – Larry Seibold – Xeon 5500 processor 1U form factor – Nehalem 95W – 0.18 to 0.22 C/W – Tcase 75C and 76 using a high performance heat sink, email May 29, 2011 IBM – M. Ellsworth – June 2, 2011, air cooling = 0.25C/W, question watts 80? or 100? Range : 0.18 to 0.27 C/W, averaging = 0.225 C/W? (group discussion needed plus watt level) Cray Inc. – G. Pautsch – Xeon processor 2U server – 0.27C/W – email May 24, 2011.
- (3) Air Cooling Heat Exchanger Air to Liquid Approach – Vette passive door data
- (4) Server Bezel Air Pre-Heating server bezel entry to cpu heat sink entry – 3C conservative number assuming only misc components in path not storage or memory modules and well controlled internal recirculation. – B. Maltz Electronic Cooling Solutions – June 2, 2011
- (5) Plate Frame Heat Exchanger Approach Plate Frame – BG P47-90-TMTL4 – 200gpm cold, 220gpm hot – cold side 62F entering – 72F leaving, warm side 74F entering, 65F leaving – Taylor 8/23/2010 LBNL ALS USB Server Room, Drawing M0.2
- (6) Liquid Direct Cooling Approach - M. Ellsworth June 2, 2011 – 0.2C/W – Greg Pautsch (Cray) 0.15C/W possible, 0.175C/W average used
- (7) Dry Fin Cooler Dry Cooler Info. – www.drycoolers.com – 10F approach typical , 5F possible with 2x # of units using pure water.
- (8) Server Liquid Pre-Heating 5C per M. Ellsworth
- (9) CDU Approach TBD


Liquid Cooled Server

Dry Cooler and Cooling Tower
 Direct Cooling Infrastructure
 CPU Case Temperature Forecast
 Compared to Intel Xeon 5500
 Tcase maximum.

Pre-Heat: allowance for inside server routing (components in series) and local pipe heating

cooling water using a dry cooler at 109°F (43°C)

cooling water using a cooling tower and plate frame heat exchanger at 90°F (32°C)




Air Cooled Server

Dry Cooler and Cooling Tower Infrastructure
 CPU Case Temperature Forecast Compared to
 Intel Xeon 5500 Tcase maximum.

Pre-Heat: allowance for heating
 from server inlet to cpu heat sink

cooling water using a dry cooler
 at 109°F (43°C)

cooling water using a cooling
 tower and plate frame hex at
 90°F (32°C)



HPC Liquid Cooling Guideline

rev. June 27, 2011

(building supplied cooling water to HPC solution)

Range Name	Building Supplied Water Temperature Range	Notes
W3	43°C (109°F) to 17.2°C (63°F)	Top of range: Use with dry cooler Bottom of range: Highest of value listed or 4°F above dew point
W2	32°C (90°F) to 17.2°C (63°F)	Top of range: Use with cooling tower Bottom of range: Highest of value listed or 4°F above dew point
W1	65F	legacy chilled water plant sites

HPC Survey

- What climatic data do we use?
- Two options:
 - 0.4% (3 hours/month) average exceeded
 - 1.0% (14 hours/month) average exceeded
- Results
 - 13 respondents
 - 69% of the respondents chose 0.4%